

Copper Lug, AWG 2#, one hole 1/4", standard barrel, with inspection window

- Copper cable lugs are designed for connecting copper cables, coils and Bus-bars.
- Copper Tube Terminals between 6mm² & 800mm² have bell • entry to ensure easy entry even for flexible conductors.
- Incorporates inspection window to check the correct cable positioning.

"colour code" help choose the right connector, the colour name is also printed in order to avoid problems for those who are colour-blind.



Product Classification		
		6006150
Material Code		000
Part Number		-
Detail Description		Copper Lug, AWG 2# , one hole 1/4", standard barrel, with inspection window
General Specifications		
Colour		Brown
Material		Copper
Tongue Type		Standard
Tongue Angle		Straight
Surface		Tin-plated
Inspection Window		With inspection window
		1/4 in 1 6 0 mm
Bolt Size		1/4 in 6.9 mm
Tang Width (C)		0.61 in 15.5 mm
Barrel length (B)		0.88 in 22.4 mm
Overall length (L) Inner diameter (ID)		1.88 in 47.8 mm 0.31 in 7.9 mm
		0.42 in 10.7 mm
Outer diameter (OD)		0.42 111 10.7 11111
Electrical Specifications		
Rating - Maximum Voltage		35KV
Environmental Specificat	ions	
Operating Temperature		-40 °C to +90°C (-40 °F to +212 °F)
For more information, please visit: ©Copyright 2023 Maxdao Inc. All rights reserved. www.maxdao.com The information contained herein is subject to change without noic changes or modify the contents of this document without prior no Revised: Mar 06, 2023 Public Public		

DATASHEET



-40 °C to +80 °C (-40 °F to +176 °F)

MAXDAO

Packaging and Weights	
Included	Lug
Packaging Quantity and UOM	1 pcs
Piece Weight	0.035 lb 0.016 kg
Certifications and Certificated	
ISO 9001:2015	Designed, manufactured and/or distributed under this quality management system
RoHS	Compliant
UL&CSA	Compliant

TEMPLATE# ITM-04-01 VERSION A/3 DATE 03/04/2023

For more information, please visit: www.maxdao.com



©Copyright 2023 Maxdao Inc. All rights reserved. The information contained herein is subject to change without notice. We reserve the right to make technical changes or modify the contents of this document without prior notice. Revised: Mar 06, 2023 Public

Page 2 of 2