MAXDAO

Copper Ferrule Lug , AWG 10#, Single Wire, Nylon-insulated

- Copper Tube Terminals between 0.14mm² & 150mm² have bell entry to ensure easy entry even for flexible conductors.
- Insulated ferrules prevent conductor breakage due to bending, wire stress or vibration, while facilitating wire insertions into the terminal block clamp.
- Fraying and breaking of wire strands is prevented and the possibility of an unreliable connection is minimized.
- Colour code meets Indian wire colour standards IS694-2010.



Product Classification		
Material Code		6004511
Detail Description		Copper Ferrule Lug , AWG 10#, Single Wire, Nylon-insulated
General Specifications		
Colour Code		Blue
Terminal Material		Copper
Insulation collar Material		Nylon
Surface		Tin-plated
Dimensions		
Barrel length (B)		0.71 in 18.0 mm
Overall length (L)		1.02 in 26.0 mm
Inner diameter (ID)		0.13 in 3.5 mm
Outer diameter (OD)		0.15 in 3.9 mm
Inner dimensions of the insulating collar (C)		0.27 in 6.9 mm
Electrical Specifications		
Rating - Maximum Voltage		35KV
Environmental Specifica	ations	
Operating Temperature		-40 °C to +90°C (-40 °F to +212 °F)
Storage Temperature		-40 °C to +80 °C (-40 °F to +176 °F)
Packaging and Weights		
Included		Lug
Packaging Quantity and UOM		Kit of 100
Piece Weight		0.088 lb 0.040 kg
For more information, please visit: ©Copyright 2023 Maxdao Inc. All rights reserved. www.maxdao.com The information contained herein is subject to change with		It notice. We reserve the right to make technical
m 🛛	changes or modify the contents of this document without prior notice. Revised: Mar 14, 2023 Public	

Certifications and Certificated

ISO 9001:2015

RoHS

UL&CSA



Designed, manufactured and/or distributed under this quality management system Compliant Compliant

For more information, please visit: www.maxdao.com



©Copyright 2023 Maxdao Inc. All rights reserved. The information contained herein is subject to change without notice. We reserve the right to make technical changes or modify the contents of this document without prior notice. Revised: Mar 14, 2023 Public

Page 2 of 2