

Copper Lug, AWG 4# , two hole 1/4", hole spacing 5/8", short barrel, with inspection window

- Copper cable lugs are designed for connecting copper cables, coils and Bus-bars
- Copper Tube Terminals between 6mm2 & 800mm2 have bell entry to ensure easy entry even for flexible conductors.
- Incorporates inspection window to check the correct cable positioning.
- The barrel length has been designed to allow easy and accurate positioning of the dies during the crimping operation.



Product Classification	
Item Number	6008489
Part Number	-
Detail Description	Copper Lug, AWG 4# , two hole 1/4", hole spacing 5/8", short barrel, with inspection window
General Specifications	
Material	Copper
Tongue Type	Standard
Tongue Angle	Straight
Surface	Tin-plated
Inspection Window	With inspection window
Dimensions	BOLT SIZE INSPECTION WINDOW T T T T T T T T T T T T T
Bolt Size	0.27 in 6.8 mm
Hole Spacing (H)	0.63 in 16.0 mm
Tang Width (C)	0.55 in 14.0 mm
Barrel length (B)	1.05 in 26.7 mm
Overall length (L)	2.56 in 65.0 mm
Inner diameter (ID)	0.28 in 7.1 mm
Outer diameter(OD)	0.38 in 9.7 mm

For more information, please visit: www.maxdao.com

©Maxdao Inc. All rights reserved.

The information contained herein is subject to change without notice. We reserve the right to make technical changes or modify the contents of this document without prior notice. Revised: Aug 30, 2024 Public DATASHEET



Rating - Maximum Voltage	35KV
Environmental Specifications	
Operating Temperature	-40 °C to +90°C (-40 °F to +212 °F)
Storage Temperature	-40 °C to +80 °C (-40 °F to +176 °F)
Packaging and Weights	
Included	Lug
Packaging Quantity and UOM	1 pcs
Piece Weight	0.07 lb 0.03 kg
Certifications and Compliance	
ISO 9001:2015	Designed, manufactured and/or distributed under this quality management system
RoHS	Compliant
UL	Compliant

For more information, please visit: www.maxdao.com

Î \square

©Maxdao Inc. All rights reserved. The information contained herein is subject to change without notice. We reserve the right to make technical changes or modify the contents of this document without prior notice. Revised: Aug 30, 2024 Public

Page 2 of 2